



ASHRAE ADDENDA



A Data Communication Protocol for Building Automation and Control Networks

Approved by the ASHRAE Standards Committee on June 25, 2011; by the ASHRAE Board of Directors on June 29, 2011; and by the American National Standards Institute on June 30, 2011.

This addendum was approved by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE Web site (www.ashrae.org) or in paper form from the Manager of Standards.

The latest edition of an ASHRAE Standard may be purchased on the ASHRAE Web site (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2011 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.



ISSN 1041-2336

**American Society of Heating, Refrigerating
and Air-Conditioning Engineers, Inc.**
1791 Tullie Circle NE, Atlanta, GA 30329
www.ashrae.org

ASHRAE Standing Standard Project Committee 135
Cognizant TC: TC 1.4, Control Theory and Application
SPLS Liaison: Richard L. Hall

David Robin, <i>Chair*</i>	J. Damian Ljungquist*	Stephen J. Treado*
Carl Neilson, <i>Vice-Chair</i>	Bryan Meyers	Klaus Wagner
Bernhard Isler, <i>Secretary*</i>	Dana Petersen	J. Michael Whitcomb*
Donald P. Alexander*	Suresh Ramachandran	Grant N. Wichenko*
Barry B. Bridges*	Frank Schubert	Christoph Zeller
Clifford H. Copass	Gregory M. Spiro	Scott Ziegenfus
Sharon E. Dinges*	Ted Sunderland	Andrey Golovin
Stephen Karg*	William O. Swan, III	Takeji Toyoda, Jr.
Simon Lemaire	David B. Thompson*	Klaus Bruno Waechter

**Denotes members of voting status when the document was approved for publication.*

ASHRAE STANDARDS COMMITTEE 2010–2011

H. Michael Newman, <i>Chair</i>	Allan B. Fraser	Janice C. Peterson
Carol E. Marriott, <i>Vice-Chair</i>	Krishnan Gowri	Douglas T. Reindl
Douglass S. Abramson	Maureen Grasso	Boggarm S. Setty
Karim Amrane	Cecily M. Grzywacz	James R. Tauby
Robert G. Baker	Richard L. Hall	James K. Vallort
Hoy R. Bohanon, Jr.	Nadar R. Jayaraman	William F. Walter
Steven F. Bruning	Byron W. Jones	Michael W. Woodford
Kenneth W. Cooper	Jay A. Kohler	Craig P. Wray
Martin Dieryckx	Frank Myers	Hugh F. Crowther, <i>BOD ExO</i>
		William P. Bahnfleth, <i>CO</i>

Stephanie C. Reiniche, *Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as “substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution.” Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- interpretation of the contents of this Standard,
- participation in the next review of the Standard,
- offering constructive criticism for improving the Standard, or
- permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

[This foreword and the “rationales” on the following pages are not part of this standard. They are merely informative and do not contain requirements necessary for conformance to the standard.]

FOREWORD

Addendum 135*ad* to ANSI/ASHRAE Standard 135-2010 contains a number of changes to the current standard. These modifications are the result of change proposals made pursuant to the ASHRAE continuous maintenance procedures and of deliberations within Standing Standard Project Committee 135. The changes are summarized below.

- 135-2010*ad*-1 This section has been removed, p. 2**
- 135-2010*ad*-2 Provide Examples of Encoding Tag Numbers Greater than 14, p. 3**
- 135-2010*ad*-3 Allow Feedback_Value to be used to calculate Elapsed_Active_Time, p. 6**
- 135-2010*ad*-4 Add READ_ACCESS_DENIED condition to ReadProperty and ReadPropertyMultiple, p. 7**
- 135-2010*ad*-5 Remove Unqualified Frame Reference in USE_TOKEN, p. 8**
- 135-2010*ad*-6 Align the Loop Object's Out_Of_Service Behavior with Other Objects, p. 9**
- 135-2010*ad*-7 Add DM-DDB-A to the Device Profile B-AAC, p. 10**
- 135-2010*ad*-8 This section was removed after the first public review, p. 11**
- 135-2010*ad*-9 Clarify Requirements for BBMDs, p. 12**
- 135-2010*ad*-10 Restrict BBMD Foreign Device Forwarding, p. 13**
- 135-2010*ad*-11 Restrict ReadRange 'Count' to INTEGER16, p. 14**

In the following document, language to be added to existing clauses of ANSI/ASHRAE 135-2010 and Addenda is indicated through the use of *italics*, while deletions are indicated by ~~strikethrough~~. Where entirely new subclauses are proposed to be added, plain type is used throughout.

135-2010ad-1 This section has been removed

135-2010ad-2 Provide Examples of Encoding Tag Numbers Greater than 14

Rationale

Recent additions to the standard have resulted in ASN.1 tag values greater than 14, which require an extra octet in the encoding, however, no examples of this were given.

[Change **Clause 20.2.15**, p. 557]

...

The context tag numbers shown in the following examples are for illustrative purposes only.

Example: Context-tagged null value

ASN.1 = [3] NULL
Context Tag = 3
Encoded Tag = X'38'

Example: Context-tagged Boolean value

ASN.1 = [6] BOOLEAN
Value = FALSE
Context Tag = 6
Encoded Tag = X'69'
Encoded Data = X'00'

Example: Context-tagged Boolean value with context tag number greater than 14

*ASN.1 = [27] BOOLEAN
Value = FALSE
Context Tag = 27
Encoded Tag = X'F9'
Tag Number Extension = X'1B'
Encoded Data = X'00'*

Example: Context-tagged unsigned integer

ASN.1 = [0] Unsigned
Value = 256
Context Tag = 0
Encoded Tag = X'0A'
Encoded Data = X'0100'

Example: Context-tagged signed integer

ASN.1 = [5] INTEGER
Value = -72
Context Tag = 5
Encoded Tag = X'59'
Encoded Data = X'B8'

Example: Context-tagged signed integer with context tag number greater than 14

*ASN.1 = [33] INTEGER
Value = -72
Context Tag = 33
Encoded Tag = X'F9'
Tag Number Extension = X'21'
Encoded Data = X'B8'*

Example: Context-tagged single precision real

ASN.1 = [0] REAL
Value = -33.3
Context Tag = 0

Encoded Tag = X'0C'
Encoded Data = X'C2053333'

Example: Context-tagged double precision real

ASN.1 = [1] Double
Value = -33.3
Context Tag = 1
Encoded Tag = X'1D'
~~Extended Length = X'08'~~
Length Extension = X'08'
Encoded Data = X'C040A66666666666'

Example: Context-tagged double precision real with context tag number greater than 14

ASN.1 = [85] Double
Value = -33.3
Context Tag = 85
Encoded Tag = X'FD'
Tag Number Extension = X'55'
Length Extension = X'08'
Encoded Data = X'C040A66666666666'

Example: Context-tagged octet string

ASN.1 = [1] OctetString
Value = X'4321'
Context Tag = 1
Encoded Tag = X'1A'
Encoded Data = X'4321'

Example: Context-tagged character string

ASN.1 = [5] CharacterString
Value = "This is a BACnet string!" (ANSI X3.4)
Context Tag = 5
Encoded Tag = X'5D'
Length Extension = X'19'
Character Set = X'00' (ANSI X3.4)
Encoded Data = X'546869732069732061204241436E657420737472696E6721'

Example: Context-tagged character string with context tag number greater than 14

ASN.1 = [127] CharacterString
Value = "This is a BACnet string!" (ANSI X3.4)
Context Tag = 127
Encoded Tag = X'FD'
Tag Number Extension = X'7F'
Length Extension = X'19'
Character Set = X'00' (ANSI X3.4)
Encoded Data = X'546869732069732061204241436E657420737472696E6721'

Example: Context-tagged bit string

ASN.1 = [0] BIT STRING
Value = B'10101'
Context Tag = 0
Encoded Tag = X'0A'
Unused Bits in Last Octet = X'03'
Encoded Data = X'A8'

...

[Change **Clause 20.2.16 Encoding of a Sequence Value**, p. 559]

...

Example: Context-tagged SEQUENCE value

```
ASN.1 =      [0] BACnetDateTime
Value =      January 24, 1991, 5:35:45.17 P.M.
Context Tag = 0
Encoded Tag = X'0E' (opening tag)
              Application Tag =Date (Tag Number = 10)
              Encoded Tag =   X'A4'
              Encoded Data =  X'5B011805'
              Application Tag = Time (Tag Number = 11)
              Encoded Tag =   X'B4'
              Encoded Data =  X'11232D11'
Encoded Tag = X'0F' (closing tag)
```

Example: Context-tagged SEQUENCE value with context tag number greater than 14

```
ASN.1 =      [47] BACnetDateTime
Value =      January 24, 1991, 5:35:45.17 P.M.
Context Tag = 47
Encoded Tag = X'FE' (opening tag)
Tag Number Extension = X'2F'
              Application Tag =      Date (Tag Number = 10)
              Encoded Tag =      X'A4'
              Encoded Data =      X'5B011805'
              Application Tag =      Time (Tag Number = 11)
              Encoded Tag =      X'B4'
              Encoded Data =      X'11232D11'
Encoded Tag = X'FF' (closing tag)
Tag Number Extension = X'2F'
```

All ASN.1 productions of sequences that contain structured elements shall have distinct tags as necessary to permit unambiguous encoding and decoding of values. The follow example illustrates this requirement.

...

135-2010ad-3 Allow Feedback_Value to be used to calculate Elapsed_Active_Time

Rationale

Mechanical systems controlled by a Binary Output object often provide additional external means to control the running state of the system, such as mechanical service-switches, security means to switch overheated motors, electrical fuses, etc. The actual active time of the mechanical system may therefore differ from the value calculated from the Present_Value. A more appropriate basis to calculate the active time may be the Feedback_Value, which indicates the effective status of the controlled mechanical system.

[Change Clause 12.7.17, p. 182]

12.7.17 Elapsed_Active_Time

This property, of type Unsigned32, represents the accumulated number of seconds that the Present_Value property *or the Feedback_Value property* has had the value ACTIVE since this property was most recently set to a zero value. If one of the optional properties Elapsed_Active_Time or Time_Of_Active_Time_Reset is present, then both of these properties shall be present. *Whether Present_Value or Feedback_Value is used as the indicator for the calculation of the Elapsed_Active_Time is a local matter.*

135-2010ad-4 Add READ_ACCESS_DENIED condition to ReadProperty and ReadPropertyMultiple

Rationale

The error code READ_ACCESS_DENIED is not included in the Error Type description clauses for the ReadPropertyMultiple and ReadProperty services. With this addition, some text from the definition of the Log_Buffer property which was incorrectly handling the ReadPropertyMultiple case is being removed.

[Change **Clause 15.5.1.3.1, Error Type**, p. 476]

15.5.1.3.1 Error Type

This parameter consists of two component parameters: (1) an 'Error Class' and (2) an 'Error Code'. See Clause 18. The 'Error Class' and 'Error Code' to be returned for specific situations are as follows:

<u>Situation</u>	<u>Error Class</u>	<u>Error Code</u>
Specified object does not exist.	OBJECT	UNKNOWN_OBJECT
Specified property does not exist.	PROPERTY	UNKNOWN_PROPERTY
An array index is provided but the property is not an array.	PROPERTY	PROPERTY_IS_NOT_AN_ARRAY
An array index is provided that is outside the range existing in the property.	PROPERTY	INVALID_ARRAY_INDEX
<i>The property is not accessible using this service.</i>	<i>PROPERTY</i>	<i>READ_ACCESS_DENIED</i>

[Change **Clause 15.7.1.3.1, Error Type**, p. 478]

15.7.1.3.1 Error Type

This parameter consists of two component parameters: (1) an 'Error Class' and (2) an 'Error Code'. See Clause 18. The 'Error Class' and 'Error Code' to be returned for specific situations are as follows:

<u>Situation</u>	<u>Error Class</u>	<u>Error Code</u>
Specified object does not exist.	OBJECT	UNKNOWN_OBJECT
Specified property does not exist.	PROPERTY	UNKNOWN_PROPERTY
An array index is provided but the property is not an array.	PROPERTY	PROPERTY_IS_NOT_AN_ARRAY
An array index is provided that is outside the range existing in the property.	PROPERTY	INVALID_ARRAY_INDEX
<i>The property is not accessible using this service.</i>	<i>PROPERTY</i>	<i>READ_ACCESS_DENIED</i>

[Change **Clause 12.25.14**, Trend Log object 'Log_Buffer', p.275]

[Change **Clause 12.27.13**, Event Log object 'Log_Buffer', p.290]

[Change **Clause 12.30.19**, Trend Log Multiple object 'Log_Buffer', p.310]

...

The buffer is not network accessible except through the use of the ReadRange service, in order to avoid problems with record sequencing when segmentation is required. ~~Attempts to read this property with the ReadProperty Request or ReadPropertyMultiple Request shall cause a Result(-) response to be issued, specifying an 'Error Class' of PROPERTY and an 'Error Code' of READ_ACCESS_DENIED.~~

135-2010ad-5 Remove Unqualified Frame Reference in USE_TOKEN

Rationale

In the SendAndWait transition of the USE_TOKEN state, a reference to frame type BACnet Data Expecting Reply appears twice. The first, unqualified, reference is an error.

[Change **Clause 9.5.6.3**, p. 105]

9.5.6.3 USE_TOKEN

...

SendAndWait

If the next frame awaiting transmission is of type Test_Request, ~~BACnet Data Expecting Reply~~, a proprietary type that expects a reply, or a frame of type BACnet Data Expecting Reply with a DestinationAddress that is not equal to 255 (broadcast),

then call SendFrame to transmit the data frame; increment FrameCount; and enter the WAIT_FOR_REPLY state.

135-2010ad-6 Align the Loop Object's Out_Of_Service Behavior with Other Objects

Rationale

In the Loop Object, it is not currently clear whether the property referenced by Manipulated_Variable_Reference is still written with the value in the Loop object's Present_Value property when Out_Of_Service is TRUE. To align the behavior of the Loop object with other objects, it is proposed that when Out_Of_Service is TRUE in the Loop object, the behavior should facilitate testing, over and above simply stopping the PID algorithm.

The following behaviors are specified for the times when Out_Of_Service is TRUE:

- the algorithm is out of service
- Present_Value is writable
- Reliability is "changeable" by unspecified means (as it is in other objects)
- changes to Present_Value are written to the property referenced by Manipulated_Variable_Reference

[Change Table 12-20, p. 230]

Table 12-20. Properties of the Loop Object Type

Property Identifier	Property Datatype	Conformance Code
...
Present_Value	REAL	R -R ⁷
...
Reliability	BACnetReliability	O -O ⁷
...

⁶ This property, if present, is required to be read only

⁷ These properties are required to be writable when Out_Of_Service is TRUE.

[Change Clause 12.17.4, p. 231]

12.17.4 Present_Value

This property indicates the current output value of the loop algorithm in units of the Output_Units property. *The Present_Value property shall be writable when Out_Of_Service is TRUE.*

[Change Clause 12.17.9, p.233]

12.17.9 Out_Of_Service

The Out_Of_Service property, of type BOOLEAN, is an indication whether (TRUE) or not (FALSE) the algorithm this object represents is or is not in service. *The Present_Value property shall be decoupled from the algorithm when the value of Out_Of_Service is TRUE. In addition, the Reliability property and the corresponding state of the FAULT flag of the Status_Flags property shall be decoupled from the algorithm when Out_Of_Service is TRUE. While the Out_Of_Service property is TRUE, the Present_Value and Reliability properties may be changed to any value as a means of simulating specific fixed conditions or for testing purposes. The property referenced by Manipulated_Variable_Reference and other functions that depend on the state of the Present_Value or Reliability properties shall respond to changes made to these properties while Out_Of_Service is TRUE, as if those changes had been made by the algorithm.*

135-2010ad-7 Add DM-DDB-A to the Device Profile B-AAC

Rationale

The standard does not include requirements to support DM-DDB-A in the device-profile B-AAC. A device claiming conformance to B-AAC is required to support AE-N-I-B. Due to the possible presence of Device Identifiers in a recipient list, the device requires support for DM-DDB-A (Who-Is initiation) to determine the physical address of the device in the recipient list.

[Change **Clause L.7**, p. 881]

L.7 Profiles of the Standard BACnet Devices

...

Device & Network Management

...	B-AAC	...
...	DM-DDB-B <i>DM-DDB-A,B</i>	...
...		...
...		...
...	DM-DOB-B	...
...	DM-DCC-B	...
...	DM-TS-B or DM-UTC-B	...
...		...
...		...
...	DM-RD-B	...
...		...

135-2010ad-8 This section was removed after the first public review.

135-2010ad-9 Clarify Requirements for BBMDs

Rationale

The standard does not clearly specify which services defined in ANNEX J are required to be supported by a BBMD.

[Change **Clause J.4.3**, p. 837]

J.4.3 BBMD Concept

Each IP subnet that is part of a B/IP network comprised of two or more subnets shall have at least one BBMD. Each BBMD shall possess a table called a Broadcast Distribution Table (BDT). If there are two or more BBMDs on a single subnet, their BDTs shall not contain any common entries in order to avoid a broadcast forwarding loop. The BDT determines which remote IP subnets receive forwarded BACnet broadcasts. To reduce BACnet broadcast traffic, it is possible to configure the BDT to forward broadcasts only to IP subnets where they are required. ~~If the BBMD has also been designated to register foreign devices as described below, it shall also possess a Foreign Device Table (FDT).~~ *A BBMD shall be able to be configured to accept Foreign Device registrations, shall support the two-hop broadcast distribution method, and shall support the execution of all BDT and FDT read and write messages defined in Clause J.2. Support for the one-hop broadcast distribution method is optional.*

135-2010ad-10 Restrict BBMD Foreign Device Forwarding

Rationale

A BBMD should only distribute messages from foreign devices which are registered.

[Change **Clause J.4.5**, p. 838]

J.4.5 BBMD Operation - Broadcast Distribution

...

Upon receipt of a BVLL Distribute-Broadcast-To-Network message from a *registered* foreign device, the receiving BBMD shall transmit a BVLL Forwarded-NPDU message on its local IP subnet using the local B/IP broadcast address as the destination address. In addition, a Forwarded-NPDU message shall be sent to each entry in its BDT as described above in the case of the receipt of a BVLL Original-Broadcast-NPDU as well as directly to each foreign device currently in the BBMD's FDT except the originating node. If the BBMD is unable to perform the forwarding function, *or the message was not received from a registered foreign device, then* it shall return a BVLC-Result message to the foreign device with a result code of X'0060' indicating that the forwarding attempt was unsuccessful.

[Change **Clause J.8.3**, p. 847]

J.8.3 B/IP-M BBMD Operation

...

Upon receipt of a BVLL Distribute-Broadcast-To-Network message from a *registered* foreign device, the receiving BBMD shall transmit a BVLL Forwarded-NPDU message using the B/IP-M group address as the destination address. In addition, a Forwarded-NPDU message shall be sent to each entry in its BDT as described in *Clause J.4.5* as well as directly to each foreign device currently in the BBMD's FDT except the originating node. Error processing is as described in *Clause J.4.5*,

135-2010ad-11 Restrict ReadRange 'Count' to INTEGER16

Rationale

For interoperability, the 'Count' parameter should not be unrestricted in size.

[Change **Clause 15.8.1.1.4**, p. 481]

15.8.1.1.4 Range

This optional parameter shall convey criteria for the consecutive range items within the referenced property that are to be returned, as described in *Clause 15.8.2*. The 'Range' parameter is shown in Table 15-14. The terminology and symbology used in this table are explained in *Clause 5.6*.

Table 15-14. Structure of the 'Range' Parameter

Parameter Name	Req	Ind	Datatype
By Position	S	S(=)	
Reference Index	M	M(=)	Unsigned
Count	M	M(=)	INTEGER <i>INTEGER16</i>
By Sequence Number	S	S(=)	
Reference Sequence Number	M	M(=)	Unsigned32
Count	M	M(=)	INTEGER <i>INTEGER16</i>
By Time	S	S(=)	
Reference Time	M	M(=)	BACnetDateTime
Count	M	M(=)	INTEGER <i>INTEGER16</i>

[Change **Clause 21**, ReadRange-Request production, p. 570]

```

ReadRange-Request ::= SEQUENCE {
    objectIdentifier      [0] BACnetObjectIdentifier,
    propertyIdentifier    [1] BACnetPropertyIdentifier,
    propertyArrayIndex   [2] Unsigned OPTIONAL,           -- used only with array datatype
    range                CHOICE {
        byPosition        [3] SEQUENCE {
            referenceIndex Unsigned,
            count          INTEGERINTEGER16
        },
        -- context tag 4 is deprecated
        -- context tag 5 is deprecated
        bySequenceNumber [6] SEQUENCE {
            referenceIndex Unsigned,
            count          INTEGERINTEGER16
        },
        byTime            [7] SEQUENCE {
            referenceTime BACnetDateTime,
            count          INTEGERINTEGER16
        }
    } OPTIONAL
}
    
```

[Change **Clause 21**, p. 582]

```

...
-- INTEGER      [APPLICATION 3], equivalent to [UNIVERSAL 2]

INTEGER16 ::= INTEGER (-32768..32767)
...
    
```

[Add a new entry to **History of Revisions**, p. 1006]

(This History of Revisions is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard.)

HISTORY OF REVISIONS

Protocol		Summary of Changes to the Standard
Version	Revision	
...
1	13	<p>Addendum ad to ANSI/ASHRAE 135-2010 Approved by the ASHRAE Standards Committee June 25, 2011; by the ASHRAE Board of Directors June 29, 2011; and by the American National Standards Institute June 30, 2011.</p> <ol style="list-style-type: none"> 1. Provide Examples of Encoding Tag Numbers Greater than 14 2. Allow Feedback_Value to be used to calculate Elapsed_Active_Time 3. Add READ_ACCESS_DENIED condition to ReadProperty and ReadPropertyMultiple 4. Remove Unqualified Frame Reference in USE_TOKEN 5. Align the Loop Object's Out_Of_Service Behavior with Other Objects 6. Add DM-DDB-A to the Device Profile B-AAC 7. Clarify Requirements for BBMDs 8. Restrict BBMD Foreign Device Forwarding 9. Restrict ReadRange 'Count' to INTEGER16

POLICY STATEMENT DEFINING ASHRAE'S CONCERN FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the standards and guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive technical committee structure, continue to generate up-to-date standards and guidelines where appropriate and adopt, recommend, and promote those new and revised standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating standards and guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.

